



# A/B/C Operator Training Fact Sheet

## BUREAU OF WEIGHTS & MEASURES

PO Box 8911  
Madison, WI 53708  
608-224-4942  
datcp.wi.gov

## RESOURCES

More information on applicable Wisconsin laws can be found at these links

**Wis. Admin. Code ATCP 93:**  
[http://docs.legis.wisconsin.gov/code/admin\\_code/atcp/090/93](http://docs.legis.wisconsin.gov/code/admin_code/atcp/090/93)

**A/B/C Operator info on our website:**  
[http://datcp.wi.gov/Consumer/Hazardous\\_Materials\\_Storage\\_Tanks/Operator\\_Training\\_Requirements/index.aspx](http://datcp.wi.gov/Consumer/Hazardous_Materials_Storage_Tanks/Operator_Training_Requirements/index.aspx)

**Class C UST Operator Certification Form:**  
<http://datcp.wi.gov/uploads/Consumer/pdf/Class%20C%20UST%20Operator%20Certification.pdf>

Any storage tank system that is required to have a permit under [Wisconsin Administrative Code ATCP 93.145](#) must meet the A/B/C Operator training requirements. This fact sheet provides an overview of the requirements. For a full list of requirements, please see [Wis. Admin. Code ATCP 93.800](#).

### Required Training

- Operator training is conducted by DATCP approved vendors. The vendor will provide proof of training upon successful completion of the training course. Proof of training must be kept on site and available for inspection.
- A list of approved training programs can be found on our [A/B/C Operator webpage](#).
- A/B Operators must receive training from an authorized training program, but C Operators may be trained by the A/B Operator. A [Class C UST Operator Certification form](#) is available on the A/B/C Operator page on our website.
- Operator training does not expire and there is no renewal requirement. Re-training may be required for operators of non-compliant storage tank systems.
- If you have questions about your A/B operator certification from another state being accepted in Wisconsin, please contact Alicia Clark at [Alicia.Clark@wisconsin.gov](mailto:Alicia.Clark@wisconsin.gov) for additional information.

### Responsibilities of Class A Operators

- Manage resources and personnel to achieve and maintain compliance with regulatory requirements.
- Ensure that appropriate individuals do all of the following:
  - Properly operate and maintain the underground storage tank system
  - Receive training to operate and maintain the underground storage tank system and keep records
  - Properly respond to emergencies or alarms relating to spills, leaks or releases from the underground storage tank system
  - Make financial responsibility documents available as required

### Responsibilities of Class B Operators

- Ensure recordkeeping and reporting requirements are met for release detection methods and release prevention equipment.
- Ensure all relevant equipment complies with performance standards
- Ensure appropriate individuals are trained to properly respond to emergencies or alarms relating to spills, leaks or releases.
- Ensure all Class C operators are provided with written instructions that include all of the following:
  - Emergency response procedures, including all of the following:
    - Procedures for overfill protection during delivery
    - Operation of emergency shut-off systems
    - Appropriate responses to all alarms
    - Reporting of leaks, spills and releases
    - Any site-specific emergency procedures
  - The name and other information needed for contacting appropriate parties if a leak, spill, release or alarm occurs

### Responsibilities of Class C Operators

- Initially responding to alarms, spills, leaks or releases
- Notifying the Class B or Class A operator and appropriate emergency responders, including 911 personnel, when necessary
- Controlling or monitoring the dispensing or sale of regulated substances